

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0554:114 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Johnson Controls, 507 E. Michigan St., Milwaukee WI 53202-5211*
Contact: *James D. Kinney (414) 524-4358 Fax (414) 276-5979

DESIGN: Model M501ML monitor module and Model M510CJ control module. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as accessories for use with separately listed compatible control units. System Sensor Model SMB500 surface mount box (CSFM Listing No. 1209:104) may be used as an enclosure for either module

NOTE: 7300-1209:104

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager